


EXISTING ASPHALT

WARNING TAPE

ASPHALT PAVING PATCH WHERE APPLICABLE



FLOWFILL
(USE 95% COMPACTED FILL
IF BELOW LANDSCAPING)

18"

18" DUCTBANK

3'-0"

#6 AWG BARE COPPER
GROUNDING CONDUCTOR

CONCRETE

DIRECT BURIED
VAULT POWER CONDUIT
(WHERE REQUIRED)

4" TYPE EB FOR POWER

2"

12" DUCTBANK

GALVANIZED THREADED ROD
TYPICAL SPACED TO SPACER
REQUIREMENTS

1 1/4"

4"

4"

SAND BASE

3"

18" TRENCH



PRIMARY CONDUIT DUCT BANK

NTS

E3B