



NOTES:

1. PROVIDE GALVANIZED METAL FLASHING AND ROOF FLASHING CONNECTIONS ACCORDING TO STANDARD DETAILS.
2. PROVIDE APPROPRIATE ELBOW-TO-FAN INLET SEPARATIONS OF 3 DUCT DIAMETERS. FOR LOCATION OF DUCT CUTOUT OR PROVIDE SEPARATE CURB.

○ FAN ROOF CURB DETAIL
 N.T.S.