



NOTES:

1. MOUNT EXCHANGERS ON FIELD-BUILT STEEL STAND.
2. POSITION VALVES AND UNIONS TO ALLOW FOR TUBE REMOVAL.
3. ALLOW ? FT CLEAR FOR TUBE REMOVAL.

HEAT EXCHANGER PIPING DETAIL

12/94