



- NOTES:
1. ARRANGE PIPING TO ALLOW COIL REMOVAL.
  2. (4) COIL CONNECTIONS SHOWN FOR CLARITY. SEE AIR HANDLING UNIT SCHEDULE FOR ACTUAL QUANTITY.
  3. ISOLATION VALVES ON TC VALVE ARE REQUIRED IF TC VALVE IS SIGNIFICANTLY SEPARATED FROM COILS.

NOTE:  
INSTALL CH PIPING ON LEAVING AIR SIDE OF COIL (TYP.)

TRAP COIL CONDENSATE PIPING AT DRAIN PAN AS SHOWN AND RUN FULL SIZE TO NEAREST FLOOR DRAIN.

# CHILLED WATER COIL PIPING DETAIL

12/94