



- WATER METER SHALL BE INSTALLED UPSTREAM OF ALL DEVICES AND WITH PROPER UPSTREAM AND DOWNSTREAM STRAIGHT PIPE LENGTHS PER DIAMETER PER MANUFACTURER SPECS.
- USE UNIONS FOR DEVICES WITHOUT INTEGRAL FLANGES.
- EACH BACKFLOW ASSEMBLY SHALL BE SIZED THE SAME AS THE BUILDING SERVICE