



- ① 5-MICRON FILTER; WILKERSON MODEL F20-04-000 OR BALSTON A912-DX
- ② 0.5-MICRON FILTER; WILKERSON MODEL M26-04-F50 OR BALSTON A912-BX
- ③ COPPER PIPING, TYPE L, SHALL BE USED.

# TEMPERATURE CONTROL AIR SUPPLY DETAIL

12/94