



DRIP LEG DIAMETER:

4" MAIN PIPE AND LESS - EQUAL TO MAIN
 5" MAIN PIPE AND MORE - 1/2" BUT NO SMALLER THAN 4"

DRIP LEG PIPE LENGTH:

12" MINIMUM OR 1-1/2 TIMES THE MAIN PIPE DIAMETER

Colorado State University FACILITIES PLANNING, DESIGN AND CONSTRUCTION STANDARDS		DRAWING: M-1B
DATE: 03/04/2021		MECHANICAL DIV.23
END OF STEAM MAIN DRIP DETAIL		