



**White Text, 5/8" Ht., Raised 1/8" Proxima Nova Regular Text Requirements per ADA:**  
 Text raised from sign surface, min. 1/32".  
 Sans serif font, all uppercase.  
 Distance between character must be a minimum of 1/8" and a maximum of 4 times the character stroke width.  
 Separated 3/8" min from Braille and pictograms.  
 Text and background must contrast.

**Braille, Grade 2, Domed, Material to Match Adjacent Panel**  
 Note that "Changing Table" text shall be used, not "Family" text in Braille.  
**Braille Requirements per ADA:**  
 Grade 2. Located directly below associated text.  
 If raised text is multi-line, Braille is placed all on one line. (If possible).  
 Ensure space for 2 lines of Braille.  
 Separated 3/8" min from text and images.  
 Braille must be domed or rounded, never flat or pointed.



**This symbol is not allowed to designate restrooms with a changing table ("family" restrooms).**

**SIGN SPECIFICATIONS**  
 Sign Material: and Colors  
 Acrylic, 1/16" to match Matthews Acrylic Paint "Dark Bronze." Non-glare per ADA.  
 Pictograms and Text: Raised white. Non-glare per ADA.

Fonts:  
 Proxima Nova.

- NOTES:**
1. CSU Environmental graphic designer to provide EPS files for fabrication.
  2. Contractor to provide shop drawings of all signs for review and approval by CSU Facilities Management Environmental Graphic Designer prior to fabrication and installation.
  3. Braille graphics are for illustrative purposes only. Actual Braille to be composed by signage fabricator. All Braille text should be verified before fabrication.
  4. Signage material, colors, and fonts may match existing or proposed interior signage system (as long as font meets ADA compliance). However, all symbols and wordings must follow this standard. Final design must be pre-approved by the CSU Inclusive Physical & Virtual Campus Committee before fabrication and installation.
  5. Any deviations from these standards must be in accordance with the current Standards for Accessible Design per the American with Disabilities Act (ADA).
  6. Sign location: Braille shall be 60 inches maximum above the floor, measured to the baseline of the braille cells.
  7. Installation varies per building and wall finish. Some walls will require fasteners instead of adhesive. Any fastener should not impede sign content. Paint fastener to match sign background.

CSU Interior Signage Standards: [www.fm.colostate.edu/signage](http://www.fm.colostate.edu/signage)

