



NOTE:
* PROVIDED BY PUMP MFR.

NOTE: RECEIVER SHALL BE MOUNTED TO ALLOW MIN. 12" FILL HEAD. LOCATE RECEIVER VENT CONNECTION AT OPPOSITE END FROM CONDENSATE INLETS.

Colorado State University FACILITIES PLANNING, DESIGN AND CONSTRUCTION STANDARDS	DRAWING: M-1E
	MECHANICAL DIV.23
DATE: 03/04/2021	
CONDENSATE PUMP SKID DETAIL	