



NOTES:

1. THIS INSTALLATION DETAIL SHALL BE UTILIZED FOR ALL PROJECTS UTILIZING DISTRICT ENERGY CHILLED WATER PIPING.
2. IN NEW INSTALLATIONS, FLOW METER PROBES SHALL BE PLACED ON DISTRICT CHILLED WATER SUPPLY AND RETURN (DCHWS & DCHWR).
3. ALL ELECTRICAL AND DATA WIRING SHALL BE IN CONDUIT PER CSU STANDARDS UNLESS OTHERWISE NOTED..

Colorado State University FACILITIES PLANNING, DESIGN AND CONSTRUCTION STANDARDS	DRAWING: U-4
	UTILITIES DIV.33
DATE: 05/06/2024	
DISTRICT CHILLED WATER UTILITY METERING DETAIL	